Shutdowns: Chilled water and steam shutdowns shall be scheduled only during off-peak seasons. Generally, the campus steam system is shut down for 1 week in late May/early June for annual maintenance and tie-in of new services. Contact Husker Energy & Power for details regarding schedule. Only University personnel are authorized to operate switches or valves on the utility distribution system.

Exterior Vaults: Vaults shall be either cast-in-place or pre-cast concrete with minimum H-20 rating, minimum 5ô x 7ô x 6ô-6ò (W x L x H). Provide lighting, one general purpose duplex outlet, sump pit with minimum 30ò depth and at least 36ò x 36ò square or 36ò diameter round dimensions, and sump pump (pump should be rated for 180Á F. water when installed in vaults serving steam systems). Hatch shall be 3ô x 3ô Bilco, or approved